

FILTRATION SIZING GUIDE (CFS STANDARD SELECTIONS)

MAIN TANK SIZE	FMEZ0380 TURN OVER	SELECTION	FMEZ0610 TURN OVER	SELECTION
1000 Gallons	3 Hours	Excellent	2 Hours	Poor
1500 Gallons	4 Hours	Excellent	3 Hours	Excellent
2000 Gallons	6 Hours	Excellent	3 hours	Excellent
2500 Gallons	7 Hours	Excellent	4 hours	Excellent
3000 Gallons	8 Hours	Excellent	5 hours	Excellent
4000 Gallons	11 Hours	Good	7 Hours	Excellent
5000 Gallons	14 Hours	Good	9 Hours	Good
6000 Gallons	16 Hours	Good	10 hours	Good
8000 Gallons	22 Hours	Poor	14 hours	Good
10,000 Gallons	27 Hours	Poor	17 Hours	Poor

MAIN TANK SIZE	FMEZ0760 TURN OVER	SELECTION	FMEZ1220 TURN OVER	SELECTION
1000 Gallons	2 Hours	Poor	1 Hour	Poor
1500 Gallons	2 Hours	Poor	2 Hours	Poor
2000 Gallons	3 Hours	Excellent	2 Hours	Poor
2500 Gallons	3 hours	Excellent	3 Hours	Excellent
3000 Gallons	4 hours	Excellent	3 hours	Excellent
4000 Gallons	5 hours	Excellent	4 hours	Excellent
5000 Gallons	7 hours	Excellent	4 hours	Excellent
6000 Gallons	8 Hours	Excellent	5 hours	Excellent
8000 Gallons	11 Hours	Good	7 Hours	Excellent
10,000 Gallons	14 Hours	Good	9 Hours	Good
12,000 Gallons	16 hours	Good	10 hours	Good
15,000 Gallons	20 Hours	Poor	13 Hours	Good
20,000 Gallons	26 hours	Poor	17 Hours	Poor

- NOTES:**
- Systems that fill multiple tanks will filter the 2nd tank on the second week of the month, the 3rd tank on the third week of the month, etc.
 - 3-8 hours turnover is considered excellent as the unit will run in one shift.
 - 9-16 hours turnover is considered good as the unit will run during two shifts.
 - Less than 3 hours and more than 16 hours run time is considered a poor choice for the cycle time, but the system can cycle up to 99 hours.